

INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification System for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX UL 18.0071X** Page 1 of 4

Certificate history: Issue 0 (2018-04-18)

Status: Current Issue No: 1

Date of Issue:

2024-07-25

Applicant:

Hotstart Inc., a Washington Company

5723 E Alki Ave. Spokane, WA 99212 United States of America

Equipment:

Immersion Heaters, EP Series, E****E-****

Optional accessory:

Type of Protection:

Flameproof "db"

Marking:

Ex db IIB T3 Gb

-40°C to +40°C

Approved for issue on behalf of the IECEx

Certification Body:

Lucy Frieders

Position:

Staff Engineer

Signature:

(for printed version)

(for printed version)

This certificate and schedule may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

UL Solutions (US) 333 Pfingsten Road Northbrook IL 60062-2096 **United States of America**





Certificate No.: IECEx UL 18.0071X Page 2 of 4

Date of issue: 2024-07-25 Issue No: 1

Manufacturer: Hotstart Inc., a Washington Company

5723 E Alki Ave. Spokane, WA 99212 United States of America

Manufacturing Hotstart Inc., a Washington

locations: Company

5723 E Alki Ave. Spokane, WA 99212 United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements

Edition:7.0

IEC 60079-1:2014

Edition:7.0

Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

US/UL/ExTR18.0080/00 US/UL/ExTR18.0080/01

Quality Assessment Report:

US/UL/QAR18.0007/04



Certificate No.: IECEx UL 18.0071X Page 3 of 4

Date of issue: 2024-07-25 Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The EP Series of Immersion heaters are immersion heaters that consist of a flameproof housing, a coupler and heating elements. The housing is internally threaded for a cover and is provided with NPT conduit entries for supply connections. The coupler is located on the opposite side of the cover and provides the means to attach the heating elements. The heating elements are resistance heating elements and vary in length and power rating depending on the model.

Please see Annex for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below:

•	Do not attempt to repair	nameproof joil	its. incomectiv	repaired joint	S Illay be	Compromisea.	Contact Hotstart for	Hameproof	onii uetans.
				The state of the s	500000000 125000				



Certificate No.: IECEx UL 18.0071X Page 4 of 4

Date of issue: 2024-07-25 Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1: Updated nomenclature to include an alternate voltage type and burr types, addition of alternate burr type/coupler materials, and drawing updated to reflect the changes. Standard IEC 60079-0 was updated to the 7th edition.

Annex:

Annex to IECEx UL 18.0071X Issue 1.pdf



Annex to Certificate No.:

IECEx UL 18.0071X

Issue No.: 1

Page 1 of 2

TYPE DESIGNATION

Nomenclature:

```
E 060 3 3 E - 25 H V - 00
```

I - E series Element

II - Wattage

III - Voltage

1 - 120V 2 - 240V 3 - 360V 4 - 480V 5 - 575V 6 - 208V/240V/480V 7 - 277V 8 - 208V 9 - 120V/208V/240V 0 - 415V A - 400V B - 200V C - 220V D - 600V

E-440V F-120V/240V G-690V J-230V

IV - Phase

1-1 Phase

3 - 3 Phase

V - Construction

E - Explosion Proof

VI - Watt Density (Watt per Square Inch)

05: 1 – 7.4WSI 10: 7.5 – 12.4WSI 15: 12.5 – 17.4WSI 20: 17.5 – 22.4WSI 25: 22.5 – 27.4WSI 30: 27.5 – 24.9WSI 30: 27.5 – 34.9WSI 40: 35 – 44.9WSI 50: 45 – 74.9WSI

VII - Thermostat

N: No Thermostat 4: 40-60°F 6: 60-80°F 8: 80-100°F 1: 100-120°F 2: 120-140°F H: 140-160°F T: Thermocouple



Annex to Certificate No.: IECEx UL 18.0071X Issue No.: 1

Page 2 of 2

R: 8in. RTD J: 165-205°F

VIII - Burr Type

V – V-Clamp Steel A – 2" NPT Aluminium S – 2" NPT Steel B – 2" NPT Stainless Steel

C - V-Clamp Stainless Steel M - M60 X 2 Steel

IX - Special Options

00 - No Special Options

0x - Sequential number starting with 01 used to define options within a custom configuration

PARAMETERS RELATING TO THE SAFETY

Maximum Voltage = 690 VAC

Maximum Power = 36kW

MARKING

Marking has to be readable and indelible; it has to include the following indications:

CAUTION: TO REDUCE RISK OF IGNITION OF HAZARDOUS ATMOSPHERES, DISCONNECT FROM SUPPLY CIRCUIT BEFORE OPENING ENCLOSURE, KEEP TIGHTLY CLOSED WHEN IN OPERATION.

WARNING: TO REDUCE THE RISK OF IGNITION OF HAZARDOUS ATMOSPHERES, CONDUIT RUNS MUST HAVE A SEALING FITTING CONNECTED WITHIN 18 INCHES OF THE ENCLOSURE FOR NORTH AMERICA ONLY ATTENTION: POUR RÉDUIRE LE RISQUE D'INFLAMMATION D'ENDROITS A RISQUE, DECONNECTER LE CIRCUIT D'ALIMENTATION AVANT D'OUVRIR LE COFFRET, LE GARDER HERMETIQUEMENT FERME PENDANT SON UTILISATION

WARNING; DO NOT OPEN WHEN AN EXPLOSIVE ATMOSPHERE IS PRESENT. SEE INSTALLATION INSTRUCTIONS.

ROUTINE EXAMINATIONS AND TESTS

Each piece of equipment defined above has to have successfully passed, before delivery:

Routine overpressure testing is required on the RTD Element in accordance with Clause 16.3 of IEC 60079-1. The test shall be conducted at a pressure of 13.5 bar (197 PSI).